


W E E K L Y O P E R A T I O N S R E P O R T

- I. DOCUMENT ID#:** CPI-OPS-7601-180701-AM1
- II. TITLE:** TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT
- III. START DATE:** 6/25/18
- IV. END DATE:** 7/1/18
- V. KEY METRICS:**
 - Cogen Production: 264,524 kWh
 - % of Gross Load Served: 68.2%
 - Net Grid After All Generation: 123,435 kWh
 - Net Exports: 22,429 kWh
 - Cogen Run-hours: 153 run-hours



- III. UNPLANNED OUTAGES:**
 1. Wednesday at 8:46 a.m. due to grid instability, technician inspected system and brought it system back online; downtime: 52 minutes. The cause seems to be an undercurrent from the grid.
 2. Sunday at 4:10 a.m. due to internal system instability, technician inspected system and brought it back online; downtime: 4:32.
- IV. OPERATING NOTES:**
 1. Cogen primary setting at 1750 kW.
 2. System taken offline on Saturday to complete oil change maintenance.
 3. Chiller module commissioning in progress.
- V. UPCOMING:**
 1. Chiller commissioning
 2. Actively working on solution to remediate tripping caused by grid.