


# W E E K L Y O P E R A T I O N S R E P O R T

- I. DOCUMENT ID#:** CPI-OPS-7601-180708-AM1
- II. TITLE:** TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT
- III. START DATE:** 7/2/18
- IV. END DATE:** 7/8/18
- V. KEY METRICS:**
  - Cogen Production: 276,690 kWh
  - % of Gross Load Served: 71.4%
  - Net Grid After All Generation: 110,594 kWh
  - Net Exports: 23,130 kWh
  - Cogen Run-hours: 162.75 run-hours



- III. UNPLANNED OUTAGES:**
  1. Monday at 11:45 p.m. due to grid instability, technician inspected system and brought it back online; downtime: 5 hours, 35 minutes. The cause seems to be an undercurrent from the grid.
- IV. OPERATING NOTES:**
  1. Cogen primary setting at 1750 kW. Reduced to 1650kW starting Friday at 12:10 p.m.
  2. Chiller module commissioning in progress.
- V. UPCOMING:**
  1. Chiller commissioning
  2. Actively working on solution to remediate tripping caused by grid.