


W E E K L Y O P E R A T I O N S R E P O R T

I. DOCUMENT ID#: **CPI-OPS-7601-180805-AM1**
II. TITLE: **TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT**
III. START DATE: **7/30/18**
IV. END DATE: **8/5/18**

V. KEY METRICS:
 Cogen Production: 287,102 kWh
 % of Gross Load Served: 77.9%
 Net Grid After All Generation: 81,296 kWh
 Net Exports: 20,213 kWh
 Cogen Run-hours: 161.25 run-hours



III. UNPLANNED OUTAGES: 1. None

IV. OPERATING NOTES:

1. Primary Cogen setting between 1750 kW and 1800 kW.
2. Brought system down Sunday morning 6:39am to prepare equipment for system test. Brought system back up at 1:23pm. Downtime 6 hours and 22 minutes.

V. UPCOMING: 1. Fill Chiller and run in test mode.