DOC ID#: CPI-OPS-7601-AM1 Issued Date: 9/4/18 Revision: 1.0

WEEKLY OPERATIONS REPORT

I. DOCUMENT ID#: CPI-OPS-7601-180902-AM1

II. TITLE: TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT


III. START DATE: 8/27/18
IV. END DATE: 9/2/18

V. KEY METRICS:

Cogen Production: 276,776 kWh

% of Gross Load Served: 69.4%

Net Grid After All Generation: 122,188 kWh
Net Exports: 17,007 kWh
Cogen Run-hours: 166 run-hours



- III. UNPLANNED OUTAGES:
- 1. Tuesday at 6:28 a.m. due to engine maintenance. Technician added water to the system and brought it back online; downtime: 1 hour and 52 minutes.
- IV. OPERATING NOTES:
- 1. Cogen ran at 1850 kW for the week.
- 2. Unscheduled dip in production on Monday approximately beginning at 12:00 p.m. thru Thursday due to internal system instability. Root cause analysis in progress with CAT factory engineer.

V. UPCOMING:

1. Scheduled maintenance will occur in September.