


# W E E K L Y O P E R A T I O N S R E P O R T

**I. DOCUMENT ID#:** CPI-OPS-7601-181014-AM1  
**II. TITLE:** TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT  
**III. START DATE:** 10/08/18  
**IV. END DATE:** 10/14/18

**V. KEY METRICS:**  
 Cogen Production: 287,126 kWh  
 % of Gross Load Served: 66.9%  
 Net Grid After All Generation: 142,254 kWh  
 Net Exports: 4,704 kWh  
 Cogen Run-hours: 158.25 run-hours



- III. UNPLANNED OUTAGES:**
- Sunday at 1:20 p.m. due to grid instability. Downtime: 10 hours and 40 minutes. Taylor operations were running minimally at the time and it was determined to wait until Monday morning to bring the system back up.
- IV. OPERATING NOTES:**
- Cogen programed to run at 1850 kW for the week, with load following.
  - Temporary drop in kW production on Thursday and Friday due to ambient heat.
- V. UPCOMING:**
- Work will continue on refrigeration unit to fully commission.