




# W E E K L Y O P E R A T I O N S R E P O R T

**I. DOCUMENT ID#:** CPI-OPS-7601-181118-AM1  
**II. TITLE:** TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT  
**III. START DATE:** 11/12/18  
**IV. END DATE:** 11/18/18

**V. KEY METRICS:**  
 Cogen Production: 292,995 kWh  
 % of Gross Load Served: ---%  
 Net Grid After All Generation: --- kWh  
 Net Exports: --- kWh  
 Cogen Run-hours: 168 run-hours



- III. UNPLANNED OUTAGES:** 1. None
- IV. OPERATING NOTES:**
1. Cogen programed to run at 1750 kW for the week along with load follow logic.
  2. Communications with the revenue meter was interrupted last week. This issue did not impact the engine’s ability to run, however the HMI was unable to collect data on Taylor’s energy usage during this time. On Monday 11/19, the revenue meter will be reset.
- V. UPCOMING:**
1. Work will continue on refrigeration unit to fully commission.