

Concentric Power Inc. 1550 Dell Ave, Ste I Campbell, CA 95008

150 S. Main St, Ste 130 Salinas, CA 93901 DOC ID#: CPI-OPS-7601-AM1 Issued Date: 429/19 Revision: 1.0

WEEKLY OPERATIONS REPORT


- I. DOCUMENT ID#:
- II. TITLE:
- III. START DATE:
- IV. END DATE:

CPI-OPS-7601-190422-AM1 TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT 4/22/19 4/28/19

V. KEY METRICS:

Cogen Production: % of Gross Load Served: Net Grid After All Generation: Net Exports: Cogen Run-hours:

250,114 kWh 87.0% 87,695 kWh 27,516 kWh 161.50 run-hours



VI. UNPLANNED OUTAGES:

- Saturday 5:07 A.M. Brought engine down to troubleshoot heat issue. Technicians repaired pump and brought system back online. Downtime: 6 hours and 30 minutes.
- VII. OPERATING NOTES:

VIII. UPCOMING:

1. Restarting M700 commissioning.

1.

2. Run engine at full capacity now that all engine repairs are complete.

Cogen programed to run at 1500 kW along with load follow logic.