

**Concentric Power Inc.** 1550 Dell Ave, Ste I Campbell, CA 95008

150 S. Main St, Ste 130 Salinas, CA 93901 DOC ID#: CPI-OPS-7601-AM1 Issued Date: 6/10/19 Revision: 1.0


# WEEKLY OPERATIONS REPORT

- I. DOCUMENT ID#:
- II. TITLE:
- III. START DATE:
- IV. END DATE:

#### CPI-OPS-7601-190603-AM1 TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT 6/03/19 6/09/19

# V. KEY METRICS:

Cogen Production: % of Gross Load Served: Net Grid After All Generation: Net Exports: Cogen Run-hours: 274,472 kWh 84.8% 49,043 kWh 31,025 kWh 162.5 run-hours



### VI. UNPLANNED OUTAGES:

- 1. CPI brought the genset down on Tuesday AM for 3 hours for routine maintenance in preparation for the SCR commissioning scheduled for Thursday and Friday.
- 2. Surge from utility brought the genset down on Wednesday AM for approximately 15 minutes.
- 3. CPI brought the genset down on Friday AM for 2 hours 15 minutes to install new sensors.

### VII. OPERATING NOTES:

1. Cogen programed to run at 1850kW along with load follow logic.

## VIII. UPCOMING:

1. Parts on order to complete SCR commissioning the week of June 17<sup>th</sup>.