


# W E E K L Y   O P E R A T I O N S   R E P O R T

**I. DOCUMENT ID#:**                      **CPI-OPS-7601-191125-AM1**  
**II. TITLE:**                                **TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT**  
**III. START DATE:**                      **12/02/19**  
**IV. END DATE:**                         **12/08/19**

**V. KEY METRICS:**  
 Cogen Production:                      206,859 kWh  
 % of Gross Load Served:              81.7%  
 Net Grid After All Generation:        46,332 kWh  
 Net Exports:                              42,991 kWh  
 Cogen Run-hours:                        122.25 run-hours



**VI. UNPLANNED OUTAGES:**            1. Low utility voltage took the genset offline Wednesday at 2:27 P.M. Voltage did not return to an acceptable tolerance until Friday. Downtime: 39 hours, 26 minutes.

**VII. OPERATING NOTES:**            1. Genset programed to run at 1750 kW with load following.

**VIII. UPCOMING:**                      1. None.