


W E E K L Y O P E R A T I O N S R E P O R T

I. DOCUMENT ID#: CPI-OPS-7601-191223-AM1
II. TITLE: TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT
III. START DATE: 12/23/19
IV. END DATE: 12/29/19

V. KEY METRICS:
 Cogen Production: 240,173 kWh
 % of Gross Load Served: 93.8%
 Net Grid After All Generation: 15,787 kWh
 Net Exports: 53,743 kWh
 Cogen Run-hours: 147.00 run-hours



- VI. UNPLANNED OUTAGES:**
- Genset tripped offline multiple times Monday, sparkplugs were replaced on Tuesday.
 - Monday 3:54 P.M. Downtime: 9 minutes.
 - Monday 4:39 P.M. Downtime: 27 minutes.
 - Monday 5:13 P.M. Downtime: 19 hours, 59 minutes.
 - Genset tripped offline due to cylinder detonation on Tuesday at 2:36 P.M. Made changes to aftercooler loop settings on Friday, will test on 12/30/2019. Downtime: 11 minutes.

VII. OPERATING NOTES:

- Genset programed to run at 1750 kW with load following.

VIII. UPCOMING:

- None.