


W E E K L Y O P E R A T I O N S R E P O R T

I. DOCUMENT ID#: CPI-OPS-7601-200203-AM1
II. TITLE: TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT
III. START DATE: 02/03/20
IV. END DATE: 02/09/20

V. KEY METRICS:
 Cogen Production: 238,624 kWh
 % of Gross Load Served: 96.1%
 Net Grid After All Generation: 9,663 kWh
 Net Exports: 48,384 kWh
 Cogen Run-hours: 149.75 run-hours



- VI. UNPLANNED OUTAGES:**
1. Genset was taken offline on Thursday at 6:30 A.M. for dry cooler cleaning and other maintenance. Downtime: 7 hours, 27 minutes.
 2. Utility outage brought the genset offline on Thursday at 6:48 P.M. Downtime: 1 hours, 57 minutes.
 3. Utility outage brought the genset offline on Sunday at 1:45 P.M. Utility power was restored at 6:55 P.M. Genset remained offline for scheduled 4,000-hour maintenance on February 10, 2020.

- VII. OPERATING NOTES:**
1. Genset programed to run at 1750 kW with load following.

- VIII. UPCOMING:**
1. 4,000-hour maintenance and jacketwater loop repair scheduled for February 10, 2020.