

Concentric Power Inc. 1550 Dell Ave, Ste I Campbell, CA 95008

150 S. Main St, Ste 130 Salinas, CA 93901 DOC ID#: CPI-OPS-7601-AM1 Issued Date: 2/18/20 Revision: 1.0

WEEKLY OPERATIONS REPORT

- I. DOCUMENT ID#:
- II. TITLE:
- III. START DATE:
- IV. END DATE:

CPI-OPS-7601-200210-AM1 TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT 02/10/20 02/16/20

V. KEY METRICS:

Cogen Production: % of Gross Load Served: Net Grid After All Generation: Net Exports: Cogen Run-hours: 0 kWh 0 % 273,982 kWh 1,900 kWh 0.00 run-hours



VI. UNPLANNED OUTAGES:

1. Genset was offline Monday for scheduled 4,000-hour maintenance. During the course of maintenance, it was discovered that coolant was intruding into the engine. A cracked head was determined to be the cause and replacement parts are estimated for delivery on February 20, 2020. Concurrent to this repair, three other heads are being replaced as preventative maintenance.

VII. OPERATING NOTES:

1. Genset offline for maintenance.

VIII. UPCOMING:

1. Genset repair is estimated to be completed on February 21, 2020.