

**Concentric Power Inc.** 1550 Dell Ave, Ste I Campbell, CA 95008

150 S. Main St, Ste 130 Salinas, CA 93901 DOC ID#: CPI-OPS-7601-AM1 Issued Date: 3/02/20 Revision: 1.0


## WEEKLY OPERATIONS REPORT

- I. DOCUMENT ID#:
- II. TITLE:
- III. START DATE:
- IV. END DATE:

## CPI-OPS-7601-200224-AM1 TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT 02/24/20 03/01/20

## V. KEY METRICS:

Cogen Production: % of Gross Load Served: Net Grid After All Generation: Net Exports: Cogen Run-hours: 140,021 kWh 53.4% 122,085 kWh 34,065 kWh 83.75 run-hours



## VI. UNPLANNED OUTAGES:

- VII. OPERATING NOTES:
- 1. None.
- 1. 4,000-hour maintenance and top-end overhaul were completed on Thursday. Downtime: 430 hours, 51 minutes.
- 2. Genset programed to run at 1750 kW with load following.

VIII. UPCOMING:

1. Post overhaul inspection tentatively scheduled for February 9, 2020.