




W E E K L Y O P E R A T I O N S R E P O R T

I. DOCUMENT ID#: CPI-OPS-7601-200316-AM1
II. TITLE: TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT
III. START DATE: 03/16/20
IV. END DATE: 03/22/20

V. KEY METRICS:
 Cogen Production: 0 kWh
 % of Gross Load Served: 0.0%
 Net Grid After All Generation: 318,017 kWh
 Net Exports: 0 kWh
 Cogen Run-hours: 0.00 run-hours



- VI. UNPLANNED OUTAGES:** 1. Genset outage due to coolant leak continues from 3/12/2020. Cylinder head has been replaced and genset is being reassembled. Two crankcase leaks are being investigated. Estimated return to operations on 4/1/2020.
- VII. OPERATING NOTES:** 1. None.
- VIII. UPCOMING:** 1. None.