




# W E E K L Y O P E R A T I O N S R E P O R T

**I. DOCUMENT ID#:** CPI-OPS-7601-200323-AM1  
**II. TITLE:** TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT  
**III. START DATE:** 03/23/20  
**IV. END DATE:** 03/29/20

**V. KEY METRICS:**  
 Cogen Production: 0 kWh  
 % of Gross Load Served: 0.0%  
 Net Grid After All Generation: 264,961 kWh  
 Net Exports: 174 kWh  
 Cogen Run-hours: 0.00 run-hours



**VI. UNPLANNED OUTAGES:**

- Genset outage due to coolant leak continues from 3/12/2020. Cylinder head has been replaced, one crankcase leak has been repaired, and genset is being reassembled. A second crankcase leak is being investigated. Estimated return to operations on 4/3/2020.

**VII. OPERATING NOTES:**

- None.

**VIII. UPCOMING:**

- None.