


W E E K L Y O P E R A T I O N S R E P O R T

I. DOCUMENT ID#: CPI-OPS-7601-200427-AM1
II. TITLE: TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT
III. START DATE: 04/27/20
IV. END DATE: 05/03/20

V. KEY METRICS:
 Cogen Production: 111,218 kWh
 % of Gross Load Served: 35.6%
 Net Grid After All Generation: 201,488 kWh
 Net Exports: 10,265 kWh
 Cogen Run-hours: 67.25 run-hours



- VI. UNPLANNED OUTAGES:**
1. Genset outage due to VFD faults on Monday at 7:13 P.M. Downtime: 13 hours, 28 minutes.
 2. Genset outage due to VFD faults on Tuesday at 10:54 A.M. Concurrent to the outage a dry cooler fan was replaced. Downtime: 23 hours, 51 minutes.
 3. Genset outage due to VFD faults on Wednesday at 5:25 P.M. Downtime: 15 hours, 50 minutes.
 4. Genset outage due to VFD faults on Thursday at 3:39 P.M. Downtime: 17 hours, 16 minutes.
 5. Genset outage due to VFD faults on Sunday at 9:59 A.M. Genset remained offline for the remainder of the weekend. Downtime: 24 hours, 35 minutes.

VII. OPERATING NOTES:

1. Genset programmed to run at 1,750 kW with load following.

VIII. UPCOMING:

1. None.