

Concentric Power Inc. 1550 Dell Ave, Ste I Campbell, CA 95008

150 S. Main St, Ste 130 Salinas, CA 93901 DOC ID#: CPI-OPS-7601-AM1 Issued Date: 6/01/20 Revision: 1.0


WEEKLY OPERATIONS REPORT

- I. DOCUMENT ID#:
- II. TITLE:
- III. START DATE:
- IV. END DATE:

CPI-OPS-7601-200525-AM1 TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT 05/25/20 05/31/20

V. KEY METRICS:

Cogen Production: % of Gross Load Served: Net Grid After All Generation: Net Exports: Cogen Run-hours: 189,756 kWh 55.6% 151,658 kWh 9,795 kWh 113.00 run-hours



VI. UNPLANNED OUTAGES:

- 1. The genset was shut down on Monday at 11:16 A.M. due to a burst coolant hose. Downtime: 25 hours, 27 minutes.
- VII. OPERATING NOTES:
- 1. Genset programmed to run at 1,750 kW with load following.
- 2. Genset shutdown Friday at 5:45 PM for planned low operations on Sunday.

VIII. UPCOMING:

1. None.