


# W E E K L Y O P E R A T I O N S R E P O R T

**I. DOCUMENT ID#:** CPI-OPS-7601-200615-AM1  
**II. TITLE:** TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT  
**III. START DATE:** 06/15/20  
**IV. END DATE:** 06/21/20

**V. KEY METRICS:**  
 Cogen Production: 130,134 kWh  
 % of Gross Load Served: 43.3%  
 Net Grid After All Generation: 170,108 kWh  
 Net Exports: 4,232 kWh  
 Cogen Run-hours: 76.00 run-hours



- VI. UNPLANNED OUTAGES:**
- Genset remained offline following cylinder detonations on June 13, 2020 after discovering two damages pushrod assemblies for cylinder #7. Repairs were completed on Wednesday. Downtime: 106 hours, 34 minutes.
- VII. OPERATING NOTES:**
- Genset programmed to run at 1,750 kW with load following.
  - Genset shut down on Saturday at 6:00 P.M. due to planned low operations on Sunday.
- VIII. UPCOMING:**
- None.