


# W E E K L Y O P E R A T I O N S R E P O R T

**I. DOCUMENT ID#:** CPI-OPS-7601-200705-AM1  
**II. TITLE:** TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT  
**III. START DATE:** 6/29/20  
**IV. END DATE:** 7/5/20

**V. KEY METRICS:**  
 Cogen Production: 203,358 kWh  
 % of Gross Load Served: -%  
 Net Grid After All Generation: \*130,791 kWh  
 Net Exports: 2,906 kWh  
 Cogen Run-hours: 121.75 run-hours



**VI. UNPLANNED OUTAGES:**

1. Tuesday 2:40 a.m. due to utility voltage. Downtime: 6 hours and 44 minutes. Technician checked the system and brought system online.

**VII. OPERATING NOTES:**

1. Genset programmed to run 1700kw in load follow.
2. Genset Shutdown Saturday at 7:26 PM due to planned low load operating schedule.
3. Fire inspection was completed successfully.
4. \* Net Grid After All Generation is slightly off because of loss of data during Tuesday morning trip.

**VIII. UPCOMING:**

1. Crank Case Ventilation System scheduled for modification inspection 7/10/20.