


# W E E K L Y O P E R A T I O N S R E P O R T

**I. DOCUMENT ID#:** CPI-OPS-7601-200830-AM1  
**II. TITLE:** TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT  
**III. START DATE:** 8/24/20  
**IV. END DATE:** 8/30/20

**V. KEY METRICS:**  
 Cogen Production: 198,185 kWh  
 % of Gross Load Served: 53.4%  
 Net Grid After All Generation: 172,833 kWh  
 Net Exports: 4,510 kWh  
 Cogen Run-hours: 117.0 run-hours



**VI. UNPLANNED OUTAGES:**

1. Friday 28<sup>th</sup> 4:30AM-6:45AM 2hrs 15min. Engine shutdown due to cylinder 3 detonation.

**VII. OPERATING NOTES:**

1. Genset programmed to run 1750kw in load follow.
2. Tuesday 25<sup>th</sup> 11:15PM – 11:00AM Wednesday 26<sup>th</sup> Replaced flex coupler on coolant loop to prevent major coolant leak. 11hrs 45min.
3. Shutdown Saturday at 8pm due to planned low load for remainder of the weekend.

**VIII. UPCOMING:**

1. Schedule to be planned for 4k hour engine service 1 weekend This September.