


# W E E K L Y   O P E R A T I O N S   R E P O R T

**I. DOCUMENT ID#:**                      **CPI-OPS-7601-201018-AM1**  
**II. TITLE:**                                **TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT**  
**III. START DATE:**                      **10/12/20**  
**IV. END DATE:**                         **10/18/20**

**V. KEY METRICS:**  
 Cogen Production:                      84,666 kWh  
 % of Gross Load Served:            20.3%  
 Net Grid After All Generation:       332,087 kWh  
 Net Exports:                             4,130 kWh  
 Cogen Run-hours:                       52.25 run-hours



**VI. UNPLANNED OUTAGES:**            1. Monday-Wednesday 7:00Pm 67Hr 0Min Hi Temp Pump failure. Parts held up in shipping. Shut down Friday afternoon for Hilliard repair with CAT.

**VII. OPERATING NOTES:**            1. Genset programmed to run 1750kw in load follow.

**VIII. UPCOMING:**                      1. None