WEEKLY OPERATIONS REPORT


I. DOCUMENT ID#: CPI-OPS-7601-210214-AM1

II. TITLE: TAYLOR COGEN GONZALES WEEKLY OPERATIONS REPORT

III. START DATE: 02/08/21 IV. END DATE: 02/14/21

V. KEY METRICS:

Cogen Production: 233,457 kWh
% of Gross Load Served: 92.5 %
Net Grid After All Generation: 19,055 kWh
Net Exports: 30,240 kWh
Cogen Run-hours: 160.00 run-hours



VI. UNPLANNED OUTAGES:

1. Thursday 2/11 The genset tripped due to utility supply voltage dipping and causing higher than acceptable Current through generator protection relay settings. 12:52 Am - 6:21 Am 5hrs, 28min. offline.

Friday 2/12 The genset tripped due to detonation conditions in cylinder 1. 1:51Pm - 2:51Pm 1hr 0 min down.

VII. OPERATING NOTES:

1. Genset programmed to run 1500kw, run through Sunday. Load followed down to allowed floor kw setpoint for longer than expected periods. Facility Load lower than typical.

VIII. UPCOMING:

1. Bias load setpoint changed from 1000 to 500, will reduce overall export.